

GOVERNMENT OF KERALA

**HEALTH SERVICE DEPARTMENT
FAMILY HEALTH CENTRE KOLATHUR
KOLATHUR PO, KOZHIKODE, KERALA 673315
phckolathur@gmail.com TEL: 04952456191**

SANITARY CERTIFICATE

Certified that I have inspected the Sri Sankara Vridha Mandiram ,kolathur in the building 2/390A in NanmindaGramapanchayath owned by Managing trustee Swami Chidanandapuri And necessary sanitary conveniences have been provided subject to the conditions laid down in the order. Violation of any one of the condition will automatically invalid this certificate and necessary Action under the provisions of Kerala Public Health Act 2023 will follow.

This certificate is issued to produce before the Board of control for Orphanages and other charitable homes kerala for Renewal License for the year 2026-2027

PLACE: KOLATHUR
DATE: 27.07.2026




**HEALTH INSPECTOR
PRIMARY HEALTH CENTRE
KOLATHUR - 673315**



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB

NARIKKUNI, KOZHIKODE

E-mail: waterqualityark@gmail.com

TEST REPORT

Report No - KWA/KKD/NRK/1452/26

Date: 17/07/2026

Customer Name & Address

HEADMISTRESS
SRISANKARA
VIDYAMANDIRAM
KOLATHUR

1. Date of Receipt	: 13/07/2026
2. Sample Name	: DRINKING WATER
3. Sampling done by	: HEALTH INSPECTOR
4. Sample Condition	: FIT FOR ANALYSIS
5. Sample Code	: 1452/26
6. Source of Sample	: WELL WATER
7. Sample Quantity	: 100 mL
8. Test performing dates	From: 13/07/2026 To: 17/07/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Coliforms	CFU/100ml	IS 15185 2016 reaffirmed 2021	Shall not be detectable in any 100ml sample	ABSI
2	E coli	CFU/100ml	IS 15185 2016 reaffirmed 2021	Shall not be detectable in any 100ml sample	ABS

TNTC: Too Numerous to Count

NB: - The results reported relate only to the sample received and tested. This test report shall not be reproduced except in full without the written approval of the laboratory.

Authorized by:

End of Report

KWA/QC/KKD/NRK/RESULT/B

Issue No. 01

Issue Date: 01/01/2022

Rev.No. 00

Rev.Date : 00

Page 3 of 3



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB
NARIKKUNI, KOZHIKODE
E-mail: waterqualitynrk@gmail.com

TEST REPORT

Date: 17/07/2026

Report No - KWA/KKD/NRK/1452/26
Customer Name & Address

**HEADMISTRESS
SRISANKARA
VIDYAMANDIRAM
KOLATHUR**

1. Date of Receipt : 13/07/2026
2. Sample Name : DRINKING WATER
3. Sampling done by : HEALTH INSPECTOR
4. Sample Condition : FIT FOR ANALYSIS
5. Sample Code : 1452/26
6. Source of Sample : WELL WATER
7. Sample Quantity : 1 LTR
8. Test performing dates From: 13/07/2026 To: 17/07/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical conductivity at 25°C	Micro mhos/Cm	IS 3025 (part 14)-2013 (Reaffirmed 2019)		55
2	Iron (as Fe)	Mg/Litre	IS 3025 (part 53)-2003 (Reaffirmed 2014)	1.0	<0.1
3	Nitrate (as NO ₃)	Mg/Litre	APHA4500NO3-B 23rd Edition	45	BDL
4	Ammonia	Mg/Litre	IS 3025 (part 34)-2008 (Reaffirmed 2019)	0.5	BDL

BDL : Below Detected Level

NB: - The results reported relate only to the sample received and tested. This test report shall not be reproduced except in full without the written approval of the laboratory.

Authorized by:

DEPUTY QUALITY MANAGER
KERALA WATER AUTHORITY
SUB DISTRICT LABORATORY
NARIKKUNI, KOZHIKODE

End of Report

Issue Date: 01/01/2022

Rev.No. 00

Rev.Date: 00

Issue No. 01

Page 2 of 3

KWA/QC/KKD/NRK/F4



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB

NARIKKUNI, KOZHIKODE

E-mail: waterqualitynrk@gmail.com

(NABL Recognized block level Government drinking water testing laboratory)

Certificate No: NABL-DWT-01006

TEST REPORT

Test Report No - KWA/KKD/NRK/1452/26

Date: 17/07/2026

Customer Name & Address	1. Date of Receipt	: 13/07/2026
HEADMISTRESS SRISANKARA VIDYAMANDIRAM KOLATHUR	2. Sample Name	: DRINKING WATER
	3. Sampling done by	: HEALTH INSPECTOR
	4. Sample Condition	: FIT FOR ANALYSIS
	5. Sample Code	: 1452/26
	6. Source of Sample	: WELL WATER
	7. Sample Quantity	: 1 LTR
	8. Test performing dates	From: 13/07/2026 To: 17/07/2026

Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Colour	HU	IS 3025 (part 4)-2021 (PLATINUM COBALT VISUAL COMPARISON METHOD)	5	<5.0
2	Odour		IS 3025 (part 5)-2018	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025 (part 10)-1984 (NEPHLOMETRIC METHOD)	1	<0.5
4	pH at 25 °C		IS 3025 (PART 11)-2022	6.5 to 8.5	5.60
5	Total Dissolved Solids (TDS) at 180°C	Mg/Litre	IS 3025 (part 16)-2023 (GRAVIMETRIC METHOD)	500	36
6	Total Hardness (as CaCO ₃)	Mg/Litre	IS 3025 (part 21)-2009 (EDTA METHOD)	200	26
7	Chloride (as Cl)	Mg/Litre	IS 3025 (part 32)-1988 (ARGENTOMETRIC METHOD)	250	10

BDL : Below Detected Level 13.0

NB: - The results reported relate only to the sample received and tested. This test report shall not be reproduced except in full without the written approval of the laboratory.

KWA/QC/KKD/NRK/F4

Issue No. 01

End of Report

Issue Date: 01/01/2022

Page 1 of 3

Authorized by:

QUALITY M...

Rev. No. 00

Rev Date: 00

DISTRICT LABORATORY

QUALITY CONTROL